


Rocky Flats Plant

OCTOBER  
1992

ER-4180110-217


# Monthly Environmental Monitoring Report

## ENVIRONMENTAL PROTECTION MANAGEMENT DEPARTMENT ENVIRONMENTAL PROTECTION AND WASTE REPORTING:

K. T. Wanebo, Coordinator  
D. A. Cirincione, Acting Manager  
N. L. Eramann, Technical Editor  
N. R. Stallcup, Desktop Publisher

### CONTRIBUTORS:

B.M. Bowen  
L.A. Dunstan  
G.R. Euler  
V.T. Guettlein  
T.G. Kalivas  
General Laboratories  
Radiological Health Laboratory

**EG&G ROCKY FLATS**

EG&G Rocky Flats, Inc.  
Rocky Flats Plant  
P.O. Box 464  
Golden, Colorado 80402-0464

A prime contractor to the  
United States Department of Energy

# Table of Contents

List of Figures .....	i
List of Tables .....	ii
August Issues .....	iii
1. Introduction .....	1-1
2. Air .....	2-1
2.1 Airborne Effluent .....	2-1
2.2 Ambient .....	2-7
Ambient Onsite Errata .....	2-13
3. Water .....	3-1
3.1 Radionuclide .....	3-1
3.2 Nonradionuclide .....	3-8
3.3 Flow .....	3-15
4. Meteorology and Climatology .....	4-1
Appendix A Radiation Standards for Protection of the Public .....	A-1
Appendix B National Pollutant Discharge Elimination System/Federal Facilities Compliance Agreement Volatile Organic Compounds .....	B-1
Appendix C Colorado Water Quality Control Commission Standards .....	C-1
Appendix D Distribution .....	D-1

## List of Figures

Figure 1 Radiological Effluent Air Sampling System .....	2-3
Figure 2 Location of Onsite and Perimeter Air Samplers .....	2-8
Figure 3 Location of Community Air Samplers .....	2-9
Figure 4 Holding and Liquid Effluent Water Courses .....	3-2
Figure 5 Wind Rose of the Rocky Flats Plant .....	4-4

## List of Tables

Table 1	Plutonium and Americium Airborne Effluent Data . . . . .	2-4
Table 2	Uranium Airborne Effluent Data . . . . .	2-5
Table 3	Tritium and Beryllium Airborne Data . . . . .	2-6
Table 4	Plutonium Concentrations in Ambient Air for Onsite Samplers . . . . .	2-10
Table 5	Plutonium Concentrations in Ambient Air for Perimeter Samplers . . . . .	2-11
Table 6	Plutonium Concentrations in Ambient Air for Community Samplers . . . . .	2-12
Table 7	Onsite Water Sample Results - Plutonium and Americium . . . . .	3-3
Table 8	Onsite Water Sample Results - Uranium . . . . .	3-4
Table 9	Offsite Water Sample Results - Plutonium and Americium . . . . .	3-5
Table 10	Offsite Water Sample Results - Uranium . . . . .	3-6
Table 11	Onsite and Offsite Water Sample Results - Tritium . . . . .	3-7
Table 12	Offsite Water Sample Results - Nitrate as Nitrogen . . . . .	3-9
Table 13	NPDES/FFCA Permit Water Sample Results . . . . .	3-10
Table 14	NPDES/FFCA Effluent Monitoring . . . . .	3-12
Table 15	Water Sample Results, Nonradioactive Parameters . . . . .	3-14
Table 16	Daily Flow Data Recorded at the Walnut Creek at Indiana Gaging Station Ponds A-4 and B-5 . . . . .	3-16
Table 17	Daily Flow Data Recorded at Ponds C-1 and C-2 (Woman Creek) . . . . .	3-17
Table 18	Daily Transfer Flow Data Recorded for Pond B-5 to Pond A-4 . . . . .	3-18
Table 19	Rocky Plant Wind Direction Frequency (Percent) by Four Wind-Speed Classes . . . . .	4-2
Table 20	Climatic Summary . . . . .	4-3

# Rocky Flats Plant Environmental Monitoring Report

## October Highlights

Summarized below are highlights from the major data categories presented. Remaining data presented in this report are within the ranges historically measured for their respective parameters and locations.

### **Tritium Airborne Effluent Calculations -**

Airborne effluent data calculations prior to October were reviewed for quality assurance. Through this review, tritium airborne effluent data for the months of January 1992 through July 1992 were found to have been incorrectly calculated and reported. In previous years, tritium release was calculated as the sum of measured releases in millicuries per location per month. During the periods in question, the reported number was calculated as the sum of the maximum concentration in microcuries per cubic meter per location per month.

The tritium airborne effluent data for the months of January through July 1992 have been recalculated as the sum of measured releases in millicuries per location per month. Table 3 of this *Monthly Environmental Monitoring Report* reflects this recalculation. The newly reported data are consistent with measurements that have been made in the past.

**RFP Laboratory Status** -In August 1992, the General Laboratory at Rocky Flats Plant (RFP) was shut down because of concerns with the secondary containment for the laboratory's aqueous process waste system. Samples for nonradioactive parameters taken under the RFP EPA National Pollutant Discharge Elimination System (NPDES) permit and normally analyzed in the General Laboratory are being sent to offsite contract laboratories for analyses. Use of offsite laboratories for analyzing these samples will continue until the General Laboratory resumes full operation.

Table 12 of this report normally lists results of nitrate analysis for Standley Lake and Great Western Reservoir samples. This sampling and analysis has been performed as an optional program for information

purposes. Because of the RFP General Laboratory shutdown discussed above, these analyses could not be performed at RFP for samples collected in September and October 1992. It was decided not to send these samples to offsite contracted laboratories for analysis in order to maximize funds available for such contractor analysis of samples required by the RFP NPDES permit. Sampling and analysis for nitrates at Standley Lake and Great Western Reservoir were discontinued effective November 1, 1992, as reported in the October 1992 *Monthly Environmental Monitoring Report*; the nitrate analysis of Table 12 will no longer be reported.

The Radiological Health Laboratory continues limited operations for radionuclide analyses. Work to upgrade secondary containment in the building is still proceeding. The date by which normal laboratory operations may resume remains uncertain. Continued delays in reporting analytical results for environmental monitoring samples are expected.

Total long-lived alpha and beta activity screening, performed on air effluent sample filters and surface water discharge samples prior to radiochemical processing and analysis, has not been affected by the difficulties with the Radiological Health Laboratories, and is continuing on schedule. Results of this screening for October are within normally expected ranges.

# 1. Introduction

The Rocky Flats Plant (RFP) has been part of a nationwide Department of Energy (DOE) complex for the research, development, and production of nuclear weapons. The plant was responsible for fabricating nuclear weapons components from plutonium, uranium, beryllium, and stainless steel. The primary production activities included metal fabrication and assembly, chemical recovery and purification of process-produced transuranic radionuclides, and related quality control functions.

This mission changed with the announcement in early 1992 that certain planned weapons systems had been canceled. RFP no longer produces weapons components, and is now in a transition phase into decontamination and disposition (D&D). Primary objectives of this new mission include achieving and maintaining compliance with environmental regulatory requirements, as well as effecting proper D&D steps that are under development.

Because radioactive and chemically hazardous materials may be used or handled at RFP during transition, the plant maintains an extensive environmental protection program. Included in that program is regular monitoring for radioactive and hazardous constituents at onsite, plant boundary, and offsite locations.

This Monthly Environmental Monitoring Report summarizes the effluent and environmental monitoring programs at the RFP for October 1992. Data presented herein reflect the best information available to the RFP at this time. If subsequent analyses indicate that any data presented herein are inaccurate or misleading, revisions will be issued promptly.

Summarized in the Executive Summary are highlights from the major data categories presented. Remaining data presented in this report are within the ranges historically measured for their respective parameters and locations.

Radiation standards for protection of the public are discussed in Appendix A of this report. The primary standards are based on calculations of radiation dose. These calculations are performed annually using monitoring data presented in the Monthly Environmental Monitoring Report. Radiation doses to the public from RFP operations are typically well below any regulatory limit and far less than are received from naturally occurring radiation sources in the Denver metropolitan area.

Appendix B lists the Volatile Organic Compounds (VOCs) for which monitoring is required under the National Pollutant Discharge Elimination System/Federal Facilities Compliance Agreement (NPDES/FFCA). Appendix C describes Colorado Water Quality Control Commission standards for the Walnut Creek and Woman Creek drainages downstream of RFP.

Error terms in the form of " $a \pm b$ " are included with some of the data. For a single sample, " $a$ " is the analytical-blank corrected value; for multiple samples it represents the arithmetic mean, the volume-weighted mean, or the annual total, as indicated in the table. The error term " $b$ " accounts for the propagated statistical counting uncertainty of the sample(s) and the associated analytical blanks at the 95 percent confidence level. These error terms represent a minimum estimate of error for the data.

Plutonium, uranium, americium, tritium, and beryllium measured concentrations are given in this report. Most of the measured concentrations are at or very near background levels, and often there is little or no amount of these materials in the media analyzed. When this occurs, the results of the laboratory analyses can be expected to show a statistical distribution of positive and negative numbers near zero and numbers that are less than the calculated minimum detectable concentration for the analyses. The laboratory analytical blanks, used to correct for background contributions to the measurements, show a similar statistical distribution around their average values. Negative sample values result when the measured value for a laboratory analytical blank is subtracted from a sample analytical result smaller than the analytical blank value. Results that are less than calculated minimum detectable levels indicate that the results are below the level of statistical confidence in the actual numerical values. All reported results, including negative values and values that are less than minimum detectable levels, are included in any arithmetic calculations on the data set. Reporting all values allows all of the data to be evaluated using appropriate statistical treatment. This assists in identifying any bias in the analyses, allows better evaluation of distributions and trends in environmental data, and helps in estimating the true sensitivity of the measurement process.

The reader should use caution in interpreting individual values that are negative or less than minimum detectable levels. A negative value has no physical significance. Values less than minimum detectable levels lack statistical confidence as to what the actual number is, although it is known with high confidence that it is below the specified

detection level. Such values should not be interpreted as being the actual amount of material in the sample, but should be seen as reflecting a range (from zero to the minimum detectable level) in which the actual amount would likely lie. These values are significant, however, when taken together with other analytical results that indicate that the distribution is near zero.

The data in this report are provided as a matter of courtesy and should not be construed as an application for a permit or license, or in support of such an application. Approval of the DOE should be obtained before publication of any data contained in this report.

Abbreviations used within this report are as defined.

### Abbreviations

C Average	Average concentration
C Maximum	Maximum concentration
C Minimum	Minimum concentration
m <sup>3</sup>	Cubic meter
m/s	Meters per second
mCi	Millicurie
mg/l	Milligrams per liter
mrem	Millirem
pCi/l	Picocuries per liter
pCi/m <sup>3</sup>	Picocuries per cubic meter
pH	Hydrogen ion concentration
SU	Standard Unit
μg/m <sup>3</sup>	Micrograms per cubic meter
#/100 ml	Number per 100 milliliter
μCi	Microcurie
μg/l	Micrograms per liter





## 2. Air

### 2.1 Airborne Effluent

RFP continuously monitors radionuclide air emissions at 53 locations in 17 buildings. The requirements outlined in the General Environmental Protection Programs (DOE Order 5400.1) and the National Emission Standards for Emissions of Radionuclides Other Than Radon From DOE Facilities (40 CFR 61, Subpart H), mandate the continuous monitoring of air emissions at all release points with the potential of discharging radionuclides into the air in quantities that could result in an effective dose equivalent (EDE) greater than 0.1 millirem per year.

The radiological particulate monitoring and sampling program uses a three-tier approach comprising Selective Alpha Air Monitors (SAAMs), total long-lived alpha screening of routine air duct emission sample filters, and radiochemical analysis of isotopes collected from air duct emission samples. This approach balances both sensitivity and timeliness of desired results. Figure 1 shows a typical radiological emission sampler configuration within an exhaust duct at the RFP.

For immediate detection of abnormal conditions, RFP building ventilation systems that service areas containing plutonium are equipped with SAAMs. SAAMs are sensitive to specific alpha particle energies and are set to detect plutonium-239 and -240. These detectors are subjected to daily operational checks, monthly performance testing and calibration for airflow, and an annual radioactive source calibration to maintain sensitivity and reliability. Monitors alarm automatically if out-of-tolerance conditions are experienced.

At regular intervals, particulate material samples from a continuous sampling system are removed from each exhaust system and radiometrically analyzed for long-lived alpha and beta emitters. The concentration of long-lived alpha and beta emitters is indicative of effluent quality and overall performance of the High Efficiency Particulate Air (HEPA) filtration system. If the total long-lived alpha concentration for an effluent sample exceeds the RFP action value of  $0.020 \times 10^{-12}$  microcuries per milliliter, a follow-up investigation is conducted to determine the cause and to evaluate the need for corrective action. The action value is equal to the most restrictive offsite Derived Concentration Guide (DCG) for plutonium activity in air.

At the end of each month, individual samples from each exhaust system are composited by location. An aliquot of each dissolved composite sample is analyzed for beryllium particulate materials. The remainder of the dissolved sample is subjected to radiochemical separation and alpha spectral analysis that quantifies specific alpha-emitting radionuclides. Analyses for uranium isotopes are conducted for each composite sample.

Forty-one of the ventilation exhaust systems are located in buildings where plutonium processing is conducted. Particulate material samples from these exhaust systems are analyzed for specific isotopes of plutonium and americium. Typically, americium contributes only a small fraction of the total alpha activity release from RFP.

Processes ventilated from several exhaust systems potentially exhibit trace quantities of tritium contamination. Impingers-type samplers are used to collect samples three times each week from the monitored locations. Tritium concentrations in the sample are measured using a liquid scintillation photospectrometer.

The calibration methodology for the beryllium analyses was changed beginning with the September 1990 samples to improve quality assurance. The previous procedure used the single-point, "simple method of additions," one of the methods recommended by the manufacturer of the graphite furnace atomic absorption analytical equipment. The current method is based on EPA Contract Laboratory Program protocol. It uses multi-point calibration curves, periodic validation of the curve with EPA validation standards, and periodic blank and sample checks to assure absence of equipment contamination and matrix effects during the analysis.

Tables 1 through 3 show monitoring results for radioactive and nonradioactive airborne effluents continuously sampled from plant buildings.




Figure 1: Radiological Effluent Air Sampling System

**Table 1****Plutonium and Americium Airborne Effluent Data**

<b>Month</b>	<b>Plutonium-239, -240</b> <b>(09/16/92 - 10/15/92)</b>		<b>Americium-241</b> <b>(08/14/92 - 09/15/92)</b>	
	<b>Release</b> <b>(<math>\mu</math>Ci)</b>	<b>C Maximum</b> <b>(pCi/m<sup>3</sup>)</b>	<b>Release</b> <b>(<math>\mu</math>Ci)</b>	<b>C Maximum</b> <b>(pCi/m<sup>3</sup>)</b>
<b>1991</b>				
Year to Date	0.843 $\pm$ 0.167	0.0030 $\pm$ 0.0006	0.1500 $\pm$ 0.0680	0.0006 $\pm$ 0.0001
<b>1992</b>				
January	0.0152 $\pm$ 0.0101 (30 of 54)	0.0005 $\pm$ 0.0001	0.0043 $\pm$ 0.0051 (40 of 54)	0.0003 $\pm$ 0.0001
February	0.0045 $\pm$ 0.0059 (37 of 53)	0.0002 $\pm$ 0.0000	-0.0001 $\pm$ 0.0052 (39 of 53)	0.0003 $\pm$ 0.0001
March	0.0028 $\pm$ 0.0027 (45 of 54)	0.0002 $\pm$ 0.0001	a	a
April	a	a	0.0013 $\pm$ 0.0030 (44 of 54)	0.0001 $\pm$ 0.0000
May	0.0132 $\pm$ 0.0116 (40 of 51)	0.0002 $\pm$ 0.0001	0.0150 $\pm$ 0.0123 (33 of 51)	0.0001 $\pm$ 0.0000
June	0.0088 $\pm$ 0.0154 (43 of 53)	0.0014 $\pm$ 0.0002	-0.0040 $\pm$ 0.0073 (43 of 53)	0.0010 $\pm$ 0.0002
July	0.0007 $\pm$ 0.0033 (44 of 56)	0.0003 $\pm$ 0.0001	0.0007 $\pm$ 0.0028 (26 of 56)	0.0001 $\pm$ 0.0001
August	0.0055 $\pm$ 0.0077 (40 of 50)	0.0001 $\pm$ 0.0000	0.0250 $\pm$ 0.0156 (37 of 50)	0.0000 $\pm$ 0.0000
September	0.0356 $\pm$ 0.0033 (39 of 55)	0.0013 $\pm$ 0.0002	0.0041 $\pm$ 0.0009 (20 of 55)	0.0001 $\pm$ 0.0000
October	b	b		

Note: Numbers in parentheses indicate amounts of laboratory analyses complete and total samples taken for that month.

a Previously reported data under review.

b Incomplete laboratory analysis.

**Table 2**

**Uranium Airborne Effluent Data**

Month	Uranium-233, -234 (09/16/92 - 10/15/92)		Uranium-238 (09/16/92 - 10/15/92)	
	Release ( $\mu\text{Ci}$ )	C Maximum ( $\text{pCi}/\text{m}^3$ )	Release ( $\mu\text{Ci}$ )	C Maximum ( $\text{pCi}/\text{m}^3$ )
1991				
Year to Date	0.629 $\pm$ 0.233	0.0001 $\pm$ 0.0001	1.002 $\pm$ 0.235	0.0005 $\pm$ 0.0002
1992				
January	-0.0189 $\pm$ 0.0102 <sup>a</sup>	0.0001 $\pm$ 0.0000	0.0071 $\pm$ 0.0131 <sup>a</sup>	0.0001 $\pm$ 0.0000
February	0.0015 $\pm$ 0.0159 (50 of 53)	0.0001 $\pm$ 0.0000	0.0208 $\pm$ 0.0210 (50 of 53)	0.0004 $\pm$ 0.0001
March	0.0022 $\pm$ 0.0099 (45 of 54)	0.0001 $\pm$ 0.0000	0.0114 $\pm$ 0.0096 (45 of 54)	0.0007 $\pm$ 0.0002
April	b	b	b	b
May	-0.0019 $\pm$ 0.0349 (47 of 51)	0.0000 $\pm$ 0.0000	0.0299 $\pm$ 0.0345 (47 of 51)	0.0001 $\pm$ 0.0000
June	-0.0408 $\pm$ 0.0265 (43 of 53)	0.0001 $\pm$ 0.0000	0.0022 $\pm$ 0.0288 (43 of 53)	0.0001 $\pm$ 0.0000
July	-0.0026 $\pm$ 0.0094 (51 of 56)	0.0000 $\pm$ 0.0000	-0.0003 $\pm$ 0.0134 (51 of 56)	0.0003 $\pm$ 0.0001
August	-0.0117 $\pm$ 0.0231 (48 of 50)	0.0001 $\pm$ 0.0000	-0.0112 $\pm$ 0.0224 (48 of 40)	0.0001 $\pm$ 0.0001
September	0.0113 $\pm$ 0.0044 (35 of 55)	0.0004 $\pm$ 0.0001	0.0676 $\pm$ 0.0134 (35 of 55)	0.0023 $\pm$ 0.0005
October	c	c	c	c

Note: Numbers in parentheses indicate amounts of laboratory analyses complete and total samples taken for that month.

- a Complete laboratory and data analysis.
- b Previously reported data under review.
- c Incomplete laboratory analysis.

**Table 3****Tritium and Beryllium Airborne Effluent Data**

Month	Tritium (H-3) (10/01/92 - 10/31/92)		Beryllium (09/15/92 - 10/15/92)	
	Release (mCi)	C Maximum (pCi/m <sup>3</sup> )	Release (grams)	C Maximum (ug/m <sup>3</sup> )
1991				
Year to Date	4.760	94 ± 55	1.2538 ± 0.083	0.00184
1992				
January	0.872	34 ± 9	0.0485 ± 0.011	0.00042
February	0.550	28 ± 15	0.0496 ± 0.009	0.00019
March	0.687	39 ± 7	a	
April	-0.029 (64 of 72)	23 ± 5	a	
May	0.000 (67 of 78)	24 ± 7	a	
June	0.278 (57 of 78)	22 ± 5	a	
July	a	a	a	
August	0.140 (20 of 30)	36 ± 5	a	
September	0.391 (64 of 66)	38 ± 16	a	
October	0.167 (72 of 78)	117 ± 27		

Note: Numbers in parentheses indicate amounts of laboratory analyses complete and total samples taken for that month.

NOTE: Beryllium measured at the remaining 44 locations was below the screening level of 0.1 gram per month. Beryllium emissions from Rocky Flats Plant are regulated by the State of Colorado under Colorado Air Quality Control Regulation #8. The limit for beryllium air emissions is 10 grams per stationary source in a 24-hour period. No blank corrections are made to any beryllium data.

a Incomplete data analysis.

## 2.2 Ambient

Ambient air samplers monitor plutonium concentrations in air in the surrounding environment. This monitoring is performed in accordance with DOE Order 5400.1. The data are used to determine the air-inhalation dose to the public for comparison with the DOE standard of 100 millirem per year effective dose equivalent from all modes of exposure from routine plant operations.

Samplers are designated in three categories by their proximity to the main facilities area. Twenty-five onsite samplers are located within RFP, generally downwind of RFP production facilities areas and near areas of known plutonium contamination. Fourteen perimeter samplers border RFP along major highways on the north (Highway 128), east (Indiana Street), south (Highway 72), and west (Highway 93) (Figure 2). Fourteen community samplers are located in metropolitan areas adjacent to RFP (Figure 3).

Samplers operate continuously at a volumetric flow rate of approximately 0.84 cubic meters per minute, collecting air particulates on 20- by 25-centimeter fiberglass filters. Manufacturer's test specifications rate this filter media to be 99.97 percent efficient for relevant particle sizes under conditions typically encountered in routine ambient air sampling.

Ambient air filters are collected biweekly and composited monthly by location before isotopic analysis. All routine ambient air filters are analyzed for plutonium-239 and -240.

Tables 4 through 6 summarize environmental monitoring data from the RFP ambient air sampling network.






Figure 2: Location of Onsite and Perimeter Air Samplers




Figure 3: Location of Community Air Samplers

**Table 4****Plutonium Concentrations in Ambient Air for Onsite Samplers****(09/28/92 - 10/26/92)**

<b>Location</b>	<b>Volume (m<sup>3</sup>)</b>	<b>Plutonium Concentration (pCi/m<sup>3</sup>)</b>	<b>± 95 percent Confidence Interval (pCi/m<sup>3</sup>)</b>
S-01a			
S-02a			
S-03a			
S-04a			
S-05a			
S-06a			
S-07a			
S-08a			
S-09a			
S-10a			
S-11a			
S-13a			
S-14a			
S-16a			
S-17a			
S-18a			
S-19a			
S-20a			
S-21a			
S-22a			
S-23a			
S-24a			
S-25a			
S-81a			

<sup>a</sup> Incomplete laboratory analysis.

**Table 5**

**Plutonium Concentrations in Ambient Air for Perimeter Samplers**

(09/22/92 - 10/20/92)

<u>Location</u>	<u>Volume</u> <u>(m<sup>3</sup>)</u>	<u>Plutonium</u> <u>Concentration</u> <u>(pCi/m<sup>3</sup>)</u>	<u>± 95 percent</u> <u>Confidence Interval</u> <u>(pCi/m<sup>3</sup>)</u>
S-31a			
S-32a			
S-33a			
S-34a			
S-35a			
S-36a			
S-37a			
S-38a			
S-39a			
S-40a			
S-41a			
S-42a			
S-43a			
S-44a			

<sup>a</sup> Incomplete laboratory analysis.

**Table 6****Plutonium Concentrations in Ambient Air for Community Samplers****(09/23/92 - 10/21/92)**

<b><u>Location</u></b>	<b><u>Community Name</u></b>	<b><u>Volume (m<sup>3</sup>)</u></b>	<b><u>Plutonium Concentration (pCi/m<sup>3</sup>)</u></b>	<b><u>± 95 percent Confidence Interval (pCi/m<sup>3</sup>)</u></b>
S-51a	Marshall			
S-52a	Jeffco Airport			
S-53a	Superior			
S-54a	Boulder			
S-55b	Lafayette			
S-56a	Broomfield			
S-57b	Walnut Creek			
S-58a	Wagner			
S-59a	Leyden			
S-60a	Westminster			
S-61 <sup>c</sup>	Denver			
S-62a	Golden			
S-68a	Lakeview Pointe			
S-73a	Cotton Creek			

a Incomplete laboratory analysis.

b This sampler was damaged beyond repair and must be replaced.

c Sampler S-61 located in Denver was inoperative during this period. This sampler has been temporarily removed because of construction activities on the building where it is installed.

**Table 4 - ERRATA AUGUST 1992**

**Plutonium Concentrations in Ambient Air for Onsite Samplers**

(07/20/92 - 08/31/92)

<u>Location</u>	<u>Number Composited Monthly Samples</u>	<u>Volume (m3)</u>	<u>Plutonium Concentration (pCi/m3)</u>	<u>± 95 percent Confidence Interval (pCi/m3)</u>
S-01 <sup>b</sup>				
S-02 <sup>a</sup>	1	39890	0.000002	0.000002
S-03 <sup>a</sup>	1	33543	0.000000	0.000001
S-04 <sup>b</sup>				
S-05 <sup>a,e</sup>	1	17935	0.000037	0.000010
S-06 <sup>a</sup>	1	37809	0.000030	0.000007
S-07 <sup>a</sup>	1	40302	0.000268	0.000054
S-08 <sup>a</sup>	1	38071	0.000779	0.000141
S-09 <sup>c</sup>	1			
S-10 <sup>a</sup>	1	39873	0.000005	0.000002
S-11 <sup>a</sup>	1	37966	0.000011	0.000003
S-13 <sup>a</sup>	1	38933	0.000001	0.000001
S-14 <sup>a</sup>	1	34252	0.000000	0.000001
S-16 <sup>a</sup>	1	39587	0.000002	0.000001
S-17 <sup>a</sup>	1	37036	0.000009	0.000003
S-18 <sup>a</sup>	1	37694	0.000019	0.000005
S-19 <sup>a</sup>	1	40015	0.000011	0.000003
S-20 <sup>a</sup>	1	38348	0.000011	0.000004
S-21 <sup>a</sup>	1	42113	0.000004	0.000003
S-22 <sup>a</sup>	1	33750	0.000005	0.000004
S-23 <sup>a</sup>	1	39014	0.000001	0.000001
S-24 <sup>a</sup>	1	28499	0.000001	0.000001
S-25 <sup>c</sup>	1			
S-81 <sup>d</sup>	1			

- a Previously reported as incomplete lab analyses.
- b Sampler was inoperable during this period.
- c Incomplete lab analysis
- d Incomplete data evaluation.
- e Sampler only operated for part of the sampling period.

**Table 4 - ERRATA SEPTEMBER 1992**

**Plutonium Concentrations in Ambient Air for Onsite Samplers**

(08/31/92 - 09/28/92)

<u>Location</u>	<u>Number Composited Monthly Samples</u>	<u>Volume (m3)</u>	<u>Plutonium Concentration (pCi/m3)</u>	<u>± 95 percent Confidence Interval (pCi/m3)</u>
S-01b				
S-02a,e	1	16241	0.000005	0.000005
S-03a	1	27345	0.000002	0.000003
S-04c				
S-05a	1	31650	0.000049	0.000012
S-06a	1	27387	0.000097	0.000022
S-07a	1	42966	0.000215	0.000048
S-08a	1	30724	0.000719	0.000124
S-09a	1	28920	0.001374	0.000252
S-10a	1	31941	0.000009	0.000004
S-11a	1	30903	0.000004	0.000003
S-13a	1	31037	0.000003	0.000003
S-14a	1	27126	0.000001	0.000001
S-16a	1	32418	0.000002	0.000002
S-17a	1	28807	0.000004	0.000005
S-18a	1	28776	0.000036	0.000009
S-19a	1	31771	0.000015	0.000006
S-20a	1	30651	0.000014	0.000006
S-21a	1	32427	0.000011	0.000005
S-22a	1	26341	0.000011	0.000005
S-23a	1	31091	0.000000	0.000002
S-24b	1			
S-25a	1	25769	0.000073	0.000017
S-81d	1			

a Previously reported as incomplete lab analyses.

b Sampler was inoperable during this period.

c Incomplete lab analysis

d Incomplete data evaluation.

e Sampler only operated for part of the sampling period.

### 3. Water

#### 3.1 Radionuclide

RFP samples for and analyzes radionuclides that may be present in the plant surface water control ponds, drinking water reservoirs, and tap water for neighboring communities. Radionuclide standards for discharge of surface water effluents are given in DOE Order 5400.5, "Radiation Protection of the Public and the Environment." In addition, the Colorado Water Quality Control Commission has issued stream segment standards for drainages downstream of RFP. These standards address both radioactive and nonradioactive parameters.


Onsite water sampling is performed at several locations at RFP. These include ponds A-4, B-5, C-1, and C-2 as well as Walnut Creek at Indiana Street. Daily samples are collected during discharges or periods of flow for these locations, and composited into weekly samples. Analyses are then performed for plutonium, americium, and uranium isotopic concentrations.

Community water monitoring includes sampling and analysis of public water supplies and tap water from several surrounding communities. Great Western Reservoir, one of the water supplies for the city of Broomfield, and Standley Lake Reservoir, a water supply for the cities of Westminster, Thornton, and Northglenn, may receive run-off from RFP drainage systems (Walnut Creek and Woman Creek respectively). However, these drainage systems have been diverted by way of the Broomfield Division Ditch since 1990. The city of Federal Heights purchases a portion of its water supply from the city of Westminster. Weekly samples are collected and composited into monthly samples, and analyses are performed for plutonium, americium, and uranium isotopic concentrations. Tritium analyses are conducted on weekly grab samples.

Drinking water from Boulder, Broomfield, and Westminster is collected weekly, composited monthly, and analyzed for plutonium, americium, and uranium isotopic concentrations. Analyses for tritium are performed weekly. Quarterly tap water samples are collected from the communities of Arvada, Denver, Golden, Lafayette, Louisville, and Thornton. These samples are analyzed for plutonium, uranium, americium, and tritium.

Water sampling results for radioactive constituents are given in Tables 7 through 11.





Note: Stream flow in the Rocky Flats area is to the east.

Figure 4: Holding Pond and Liquid Effluent Water Courses

**Table 7****Onsite Water Sample Results - Plutonium and Americium**

Holding Pond Outfall (pCi/l)		
<u>Location</u>	<u>Plutonium-239, -240</u>	<u>Americium-241</u>
<u>Pond A-4</u>		
10/20/92 - 10/23/92	a	a
10/24/92 - 10/28/92	a	a
Volume weighted average concentration	a	a
<u>Pond B-5</u> - No discharge		
<u>Pond C-1</u>		
10/03/92 - 10/09/92	0.001 ± 0.002	a
10/10/92 - 10/16/92	a	a
10/17/92 - 10/23/92	a	a
10/24/92 - 10/30/92	a	a
Average concentration	a	a
<u>Pond C-2</u> - No discharge		
<u>Walnut Creek at Indiana</u>		
10/21/92 - 10/23/92	a	a
10/24/92 - 10/28/92	a	a
Volume weighted average concentration	a	a

a Incomplete laboratory analysis.

**Table 8**

**Onsite Water Sample Results - Uranium**

Holding Pond Outfall (pCi/l)		
<u>Location</u>	<u>Uranium-233, -234</u>	<u>Uranium-238</u>
<u>Pond A-4</u>		
10/20/92 - 10/23/92	a	a
10/24/92 - 10/28/92	a	a
Volume weighted average concentration	a	a
<u>Pond B-5</u> - No discharge		
<u>Pond C-1</u>		
10/03/92 - 10/09/92	a	a
10/10/92 - 10/16/92	a	a
10/17/92 - 10/23/92	a	a
10/24/92 - 10/30/92	a	a
Average concentration	a	a
<u>Pond C-2</u> - No discharge		
<u>Walnut Creek at Indiana</u>		
10/21/92 - 10/23/92	a	a
10/24/92 - 10/28/92	a	a
Volume weighted average concentration	a	a

a Incomplete laboratory analysis.

**Table 9****Offsite Water Sample Results - Plutonium and Americium**

<u>Location</u>	<u>Number of Samples</u>	<u>Reservoirs (pCi/l)</u>	
		<u>Plutonium-239, -240</u>	<u>Americium-241</u>
Great Western	1 <sup>a</sup>	b	b
Standley Lake	1 <sup>a</sup>	b	b
 <u>Community Tap Water (pCi/l)<sup>a</sup></u>			
Broomfield	1 <sup>a</sup>	b	b
Westminster	1 <sup>a</sup>	b	b

- <sup>a</sup> Plutonium and americium analyses were performed on one sample composited from four weekly grab samples.  
<sup>b</sup> Incomplete laboratory analysis.

**Table 10****Offsite Water Sample Results - Uranium****Reservoirs (pCi/l)**

<u>Location</u>	<u>Number of Samples</u>	<u>Uranium-233, -234</u>	<u>Uranium-238</u>
Great Western	1 <sup>a</sup>	b	b
Standley Lake	1 <sup>a</sup>	b	b

**Community Tap Water (pCi/l)<sup>a</sup>**

Broomfield	1 <sup>a</sup>	b	b
Westminster	1 <sup>a</sup>	b	b

<sup>a</sup> Uranium analyses were performed on one sample composited from four weekly grab samples.

<sup>b</sup> Incomplete laboratory analysis.

**Table 11****Onsite and Offsite Water Sample Results - Tritium**

Tritium (pCi/l)

<u>Location</u>	<u>Number of Samples</u>	<u>C Minimum</u>	<u>C Maximum</u>	<u>C Average</u>
Pond A-4 <sup>b</sup>	9	a	a	a
Pond C-1	4	a	a	a
Broomfield	5	a	a	a
Great Western	5	a	a	a
Standley Lake	5	a	a	a
Westminster	5	a	a	a
Walnut at Indianab	8	a	a	a

<sup>a</sup> Incomplete laboratory analysis.<sup>b</sup> Volume weighted average concentration.

### 3.2 Nonradionuclide

RFP conducts sitewide surface water sampling programs to monitor discharges from detention ponds, evaluate potential contaminant releases, and characterize baseline water quality. For nonradioactive parameters requirements for this monitoring are derived from the RFP EPA National Pollutant Discharge Elimination System (NPDES) permit as modified in March 1991, by a Federal Facilities Compliance Agreement (FFCA). The NPDES/FFCA permit sets limits for nonradioactive pollutants in effluent water from federal facilities.

The EPA has issued to the RFP an NPDES permit for control of surface water discharges. The RFP NPDES permit establishes effluent limitations for seven surface water discharge points, which may discharge into drainages leading off of the RFP.

Nitrate monitoring for Great Western Reservoir and Standley Lake, the two drinking water reservoirs that may receive surface water discharges from the plant, are summarized in Table 12. Surface water discharges from RFP are currently being diverted around these drinking water reservoirs.

Water sampling results associated with the NPDES/FFCA permit are reported in Table 13. Applicable NPDES/FFCA limits are included in Table 13 for comparison. Monitoring results for which no limits have been established under the NPDES/FFCA are reported in Table 14. Analytical results for nonradioactive parameters in water at Walnut Creek at the Indiana Street location are summarized in Table 15.

**Table 12****Offsite Water Sample Results - Nitrate as Nitrogen****Nitrate (as N) at Great Western Reservoir**

<u>Sample Date</u>	<u>Nitrate (as N) (mg/l)</u>
10/01/92	a
10/08/92	a
10/15/92	a
10/22/92	a
10/29/92	a

**Nitrate (as N) at Standley Lake**

10/01/92	a
10/08/92	a
10/15/92	a
10/22/92	a
10/29/92	a

a Samples were collected but not analyzed.

**Note:** For some nonradioactive parameters, the concentrations that are measured at or below the Minimum Detectable Concentration (MDC) are assigned to MDC. The less than symbol (<) indicates MDC values and calculated values that include one or more MDCs.



**Table 13**

**NPDES/FFCA Permit Water Sample Results**

**Discharge 001-A (Pond B-3)** Discharged continuously from 10/01/92 - 10/31/92.

<u>Parameters</u>		<u>Measured 30-Day Average</u>	<u>Limit 30-Day Average</u>	<u>Measured Max. 7-Day Average</u>	<u>Limit Max. 7-Day Average</u>
Nitrate	mg/l	3	10	5	20
Total Residual Chlorine	mg/l		<u>Measured Maximum</u> 0.08	<u>Limit Maximum</u> 0.5	

**Discharge 001-B (Sewage Treatment Plant)** Discharged continuously from 10/01/92 - 10/31/92.

<u>Parameters</u>		<u>Measured 30-Day Average</u>	<u>Limit 30-Day Average</u>	<u>Measured Maximum</u>	<u>Limit Maximum</u>
CBOD <sub>5</sub>	mg/l	1	10	1	25
Total Phosphorus	mg/l	0.01	8	0.6	12
Total Chromium	mg/l	0.005	0.05	0.006	0.10
		<u>Measured 30-Day Average</u>	<u>Limit 30-Day Average</u>	<u>Measured Max. 7-Day Average</u>	<u>Limit Max. 7-Day Average</u>
Fecal Coliforms	#/100 ml	1 (Geometric)	200 (Geometric)	1 (Geometric)	400 (Geometric)
Total Suspended Solids	mg/l		30		45
		<u>Measured Minimum</u>	<u>Limit Minimum</u>	<u>Measured Maximum</u>	<u>Limit Maximum</u>
pH	SU	6.6	6.0	7.2	9.0
		<u>Observed Sheen</u>	<u>Limit Sheen</u>		
Oil and Grease		No visual	No visual		

**Discharge 002 (Pond A-3)** No discharge.

<u>Parameters</u>		<u>Measured 30-Day Average</u>	<u>Limit 30-Day Average</u>	<u>Measured Maximum</u>	<u>Limit Maximum</u>
Nitrates as N	mg		10		20
		<u>Measured Minimum</u>	<u>Limit Minimum</u>	<u>Measured Maximum</u>	<u>Limit Maximum</u>
pH	SU		6.0		9.0

**Table 13**

**NPDES/FFCA Permit Water Sample Results (Continued)**

*Discharge 003 (RO Pilot Plant) and Discharge 004 (RO Plant) are inactive outfalls and will be eliminated from the new NPDES permit.*

**Discharge 005 (Pond A-4)** Discharged continuously from 10/20/92 - 10/28/92.

<u>Parameters</u>		<u>Measured Maximum</u>	<u>Limit Maximum</u>
Total Chromium	mg/l	<0.006	0.05

**Discharge 006 (Pond B-5)** No discharge.

<u>Parameters</u>		<u>Measured 30-Day Average</u>	<u>Limit 30-Day Average</u>	<u>Measured Max. 7-Day Maximum</u>	<u>Limit Max. 7-Day Maximum</u>
Nitrate as Na <sup>a</sup>	mg/l		10		20
			<u>Measured Maximum</u>	<u>Limit Maximum</u>	
Total Residual Chlorine <sup>a</sup>	mg/l			0.5	
Total Chromium	mg/l			0.05	

**Discharge 007 (Pond C-2)** No discharge.

<u>Parameters</u>		<u>Measured Maximum</u>	<u>Limit Maximum</u>
Total Chromium	mg/l		0.05

<sup>a</sup> These parameters are measured only in the event that Waste Water Treatment Plant effluent bypasses Pond B-3 and flows directly into Pond B-5.

**Table 14**

**NPDES/FFCA Effluent Monitoring**

**Discharge 001-A (Pond B-3)** Discharged continuously from 10/01/92 - 10/31/92.

<u>Parameters</u>		<u>Measured Maximum</u>	<u>Measured 30-Day Average</u>
BOD5	mg/l	5	3
CBOD5	mg/l	2	1
Total Suspended Solids	mg/l	22	9

**Discharge 001-B (Sewage Treatment Plant [STP])** Discharged continuously from 10/01/92 - 10/31/92.

<u>Parameters</u>		<u>Measured Maximum</u>	<u>Measured 30-Day Average</u>
Nitrate as N	mg/l	4.2	3.5
Total Residual Chlorine	mg/l	0.06	0.01

**Whole Effluent Toxicity<sup>a</sup>** Sampled quarterly; data reported 9/92.

Ceriodaphnia % Eff to LC<sub>50</sub>:  
Fathead Minnows % Eff to LC<sub>50</sub>:

<u>Metals</u>		<u>Measured 30-Day Average</u>
Antimony	µg/l	<38
Arsenic	µg/l	<0.8
Beryllium	µg/l	<0.3
Cadmium	µg/l	<4.6
Copper	µg/l	<5.0
Iron	µg/l	27.5
Lead	µg/l	3.7
Manganese	µg/l	20
Mercury	µg/l	0.6
Nickel	µg/l	<6.1
Silver	µg/l	<5.0
Zinc	µg/l	43

Metals were sampled on 10/07/92 and 10/14/92.

		<u>PQL<sup>b</sup></u>	<u>Concentrations above PQL</u>	
Volatile Organic Compounds (VOCs)	µg/l			
Methylene chloride	µg/l	5	5	sampled 10/07/92
Methylene chloride	µg/l	5	6	sampled 10/21/92
Chloroform	µg/l	5	5	sampled 10/21/92

## Table 14

### NPDES/FFCA Effluent Monitoring (Continued)

*Discharge 003 (Reverse Osmosis Pilot Plant) and Discharge 004 (Reverse Osmosis Plant) are inactive outfalls and will be eliminated from the new NPDES permit.*

*Discharge 005 (Pond A-4)* Discharged continuously from 10/20/92 - 10/28/92.

Whole Effluent Toxicity<sup>a</sup>                      Sampled quarterly; data reported 9/92.

Ceriodaphnia	% Eff to LC <sub>50</sub> :
Fathead Minnows	% Eff to LC <sub>50</sub> :

*Discharge 006 (Pond B-5)*      No discharge.

Whole Effluent Toxicity<sup>a</sup>

Ceriodaphnia	% Eff to LC <sub>50</sub> :
Fathead Minnows	% Eff to LC <sub>50</sub> :

*Discharge 007 (Pond C-2)*      No discharge.

Whole Effluent Toxicity<sup>a</sup>

Ceriodaphnia	% Eff to LC <sub>50</sub> :
Fathead Minnows	% Eff to LC <sub>50</sub> :

- <sup>a</sup> Results for whole effluent toxicity are given in percentage of effluent sample that will cause mortality to half the test result organisms within the time frame of the test. For example, >100 percent indicates that 100 percent pure effluent did not cause acute toxicity to at least half of the organisms. A lower percentage LC<sub>50</sub> (lethal concentration to 50 percent of test organisms) indicates a greater toxic effect since less of the sample is required to observe a sufficiently extensive adverse effect.
- <sup>b</sup> PQL is the Practical Quantitation Limit. It is equal to ten times the Method Detection Limit and represents the quantity at which 70 percent of laboratories can report in the 95 percent confidence interval.

**Table 15**

**Water Sample Results, Nonradioactive Parameters**

**Walnut Creek at Indiana Street**

<u>Parameters</u>		<u>Number of Samples</u>	<u>C Minimum</u>	<u>C Maximum</u>	<u>C Average</u>
pH	SU	8	7.23	8.18	N/A
Nitrates as N	mg/l	8	0.57	0.83	0.72

### 3.3 Flow

Daily flow data for surface water from the two plant drainage systems (Walnut Creek and Woman Creek) are given in Tables 16 and 17. The current NPDES/FFCA permit requires flow measurement for terminal ponds when discharged offsite (A-4, B-5, and C-2). Other flow data are reported for informational purposes.

Daily flow data for water transferred from Pond B-5 to Pond A-4, for subsequent discharge offsite, are given in Table 18. Meteorological data are given in Tables 19 and 20.

**Table 16****Daily Flow Data Recorded at the Walnut Creek at Indiana Gaging Station, Ponds A-4 and B-5**

<u>Date</u>	<u>Walnut Creek at Indiana (Gallons)</u>	<u>Pond A-4 (Gallons)</u>	<u>Pond B-5 (Gallons)</u>
10/01/92	No flow	No discharge	No discharge
10/02/92			
10/03/92			
10/04/92			
10/05/92			
10/06/92			
10/07/92			
10/08/92			
10/09/92			
10/10/92			
10/11/92			
10/12/92			
10/13/92			
10/14/92			
10/15/92			
10/16/92			
10/17/92			
10/18/92			
10/19/92	No flow	No discharge	
10/20/92	250,000	485,000	
10/21/92	763,000	1,070,000	
10/22/92	920,000	993,000	
10/23/92	1,021,000	1,060,000	
10/24/92	994,000	1,020,000	
10/25/92	1,074,000	1,170,000	
10/26/92	1,048,000	1,130,000	
10/27/92	936,000	1,110,000	
10/28/92	760,000	870,000	
10/29/92	No flow	No discharge	
10/30/92			
10/31/92	No flow	No discharge	No discharge
Total	7,766,000	8,908,000	No discharge

**Table 17**

**Daily Flow Data Recorded at Ponds C-1 and C-2 (Woman Creek)**

<u>Date</u>	<u>Pond C-1 (Gallons)</u>	<u>Pond C-2 (Gallons)</u>
10/01/92	Low flow	No discharge
10/02/92		
10/03/92		
10/04/92		
10/05/92		
10/06/92	Low flow	
10/07/92	23,000	
10/08/92	20,000	
10/09/92	28,000	
10/10/92	26,000	
10/11/92	24,000	
10/12/92	44,000	
10/13/92	31,000	
10/14/92	41,000	
10/15/92	46,000	
10/16/92	62,000	
10/17/92	67,000	
10/18/92	58,000	
10/19/92	53,000	
10/20/92	44,000	
10/21/92	47,000	
10/22/92	57,000	
10/23/92	65,000	
10/24/92	70,000	
10/25/92	86,000	
10/26/92	199,000	
10/27/92	103,000	
10/28/92	90,000	
10/29/92	101,000	
10/30/92	105,000	
10/31/92	107,000	No discharge
Total	1,597,000	No discharge



**Table 18****Daily Transfer Flow Data Recorded for Pond B-5 to Pond A-4**

<u>Date</u>	<u>Pond B-5 to Pond A-4 (Gallons)</u>
10/01/92	No transfer
10/02/92	
10/03/92	
10/04/92	
10/05/92	
10/06/92	
10/07/92	
10/08/92	
10/09/92	
10/09/92	
10/10/92	
10/11/92	
10/12/92	
10/13/92	
10/14/92	
10/15/92	
10/16/92	
10/17/92	
10/18/92	
10/19/92	
10/20/92	
10/21/92	
10/22/92	
10/23/92	
10/24/92	
10/25/92	
10/26/92	
10/27/92	No transfer
10/28/92	345,000
10/29/92	53,000
10/30/92	835,000
10/31/92	1,109,000
Total	2,342,000

## 4. Meteorology and Climatology

Meteorological data are routinely collected on the plantsite from instrumentation installed on a 61-meter (200-foot) tower located in the west buffer zone. Meteorological data recovery was nearly 100 percent for October. Table 19 is the October 1992 summary of the percent frequency of wind directions (16 compass points) divided into four wind-speed categories. The compass point designations indicate the true bearing when facing against the wind. These frequency values are represented graphically in the accompanying wind rose. The wind rose vectors also represent the bearing against the wind (i.e., wind along each vector blows toward the center).

Winds at RFP generally occur from the west through northwest, especially when speeds are greater than 3 m/s (6.7 mph). At lighter wind speeds less than 3 m/s (6.7 mph), the distribution of wind direction is more even. Wind speeds greater than 7 m/s (15.7 mph) from the east-southeast through south occur infrequently. The distribution of winds during October was typical.

October was cooler and drier than normal. The month was generally tranquil as only a few storms affected RFP weather. The high temperature averaged near-normal, with the maximum of 26 degrees centigrade (26 °C) (79 degrees Fahrenheit [79 °F]) occurring on October 13. The clear and dry conditions caused the overnight temperatures to average below normal. The coldest temperature of 20 °F (-6.7 °C) occurred on the morning of October 16.

The mean wind speed during October was 3.3 m/s (7.4 mph). The wind speeds were quite low during the month, indicating the absence of strong storms. The peak gust during the month was a modest 22 m/s (49 mph), which occurred on October 8. The mean temperature recorded for October was 10.8 °C (51.4 °F), or about 0.6 centigrade degrees (1 Fahrenheit degree) below normal.

Precipitation totalled 0.59 inches (1.5 cm) during October, slightly below the normal of 0.83 inches (2.1 cm). Much of the total occurred on October 25, when 0.40 inches (1.0 cm) fell. Annual precipitation through October stood at 12.80 inches (32.5 cm), or nearly 2 inches (5 cm) below normal.

**Table 19**

**Rocky Flats Plant Wind Direction Frequency (Percent) by Four Wind-Speed Classes**

(Fifteen-Minute Averages - October 1992)

	<u>Calm</u>	<u>1-3</u> <u>(m/s)</u>	<u>3-7</u> <u>(m/s)</u>	<u>7-15</u> <u>(m/s)</u>	<u>&gt;15</u> <u>(m/s)</u>	<u>Total</u>
N	-	3.39	4.30	0.13	0.00	7.83
NNE	-	3.36	2.59	0.40	0.00	6.36
NE	-	1.78	1.61	0.27	0.00	3.67
ENE	-	1.95	0.77	0.07	0.00	2.79
E	-	2.76	0.61	0.00	0.00	3.36
ESE	-	3.43	0.84	0.00	0.00	4.27
SE	-	4.13	2.18	0.00	0.00	6.32
SSE	-	3.33	1.41	0.00	0.00	4.74
S	-	2.86	1.82	0.03	0.00	4.71
SSW	-	2.15	1.71	0.00	0.00	3.87
SW	-	3.03	2.55	0.00	0.00	5.58
WSW	-	3.09	4.87	0.07	0.00	8.04
W	-	3.73	4.10	1.38	0.00	9.21
WNW	-	4.61	4.37	1.92	0.00	10.89
NW	-	3.36	4.44	0.57	0.00	8.37
NNW	-	3.83	3.80	0.13	0.00	7.77
TOTAL	2.27	50.79	41.97	4.97	0.00	100.00

**Table 20**

**Climatic Summary**

TEMPERATURE AND DEWPOINT					WIND SPEED		PRECIPITATION	PRESSURE	SOLAR	
Date	High (°F)	Low	Mean	Dew- point	Mean (mph)	Maximum (1 sec)	Total Inches	Maximum (15 min)	Actual Mean (Millibars)	Total
10/01/92	78.1	56.1	67.1	23.2	6.0	14.3	0.00	0.00	819	5.16
10/02/29	76.6	57.0	66.8	23.0	5.8	15.4	0.00	0.00	815	5.14
10/03/92	75.6	55.4	65.5	25.7	6.3	18.8	0.00	0.00	811	5.05
10/04/92	71.6	48.9	60.3	28.0	7.6	29.8	0.00	0.00	812	4.74
10/05/92	57.6	43.7	50.7	29.3	5.8	15.9	0.08	0.01	818	3.89
10/06/92	47.7	38.3	43.0	30.0	8.5	29.1	0.02	0.01	815	2.31
10/07/92	43.5	29.1	36.3	13.3	9.6	33.6	0.04	0.01	816	3.17
10/08/92	56.5	27.0	41.8	11.8	11.2	48.8	0.00	0.00	810	4.51
10/09/92	58.1	38.8	48.5	19.8	12.5	41.8	0.00	0.00	810	3.70
10/10/92	59.9	35.8	47.9	23.9	6.7	27.1	0.00	0.00	817	4.58
10/11/92	73.6	53.2	63.4	24.1	10.7	29.5	0.00	0.00	818	4.63
10/12/92	75.6	43.3	59.5	23.7	10.1	41.2	0.00	0.00	815	3.73
10/13/92	78.8	37.8	58.3	21.6	9.8	35.3	0.00	0.00	809	3.36
10/14/92	54.1	33.3	43.7	24.1	5.1	14.5	0.00	0.00	809	4.04
10/15/92	66.4	25.3	45.9	20.3	7.2	38.0	0.00	0.00	813	4.24
10/16/92	53.8	19.9	36.9	16.0	5.6	15.0	0.00	0.00	815	3.69
10/17/92	66.4	33.6	50.0	21.2	8.9	36.5	0.00	0.00	816	4.11
10/18/92	64.6	31.5	48.1	20.5	6.5	21.5	0.00	0.00	816	3.23
10/19/92	71.8	46.4	59.1	24.6	7.2	31.5	0.00	0.00	813	3.12
10/20/92	72.7	44.8	58.8	22.6	6.7	16.8	0.00	0.00	815	4.03
10/21/92	74.8	54.0	64.4	25.7	8.5	31.1	0.00	0.00	815	3.57
10/22/92	70.5	32.0	51.3	28.8	8.3	21.5	0.00	0.00	820	3.54
10/23/92	62.4	48.2	55.3	28.4	6.5	17.0	0.00	0.00	826	3.52
10/24/92	70.3	48.0	59.2	27.5	5.8	13.9	0.00	0.00	820	3.63
10/25/92	68.2	40.6	54.4	29.8	7.4	24.4	0.40	0.08	815	1.77
10/26/92	60.3	35.8	48.1	28.6	5.8	17.2	0.01	0.01	815	3.72
10/27/92	64.9	43.3	54.1	28.4	6.3	25.3	0.00	0.00	813	3.33
10/28/92	46.2	28.8	37.5	21.9	7.4	16.8	0.00	0.00	811	1.16
10/29/92	40.5	28.8	34.7	23.5	3.4	9.6	0.00	0.00	806	1.09
10/30/92	55.9	30.7	43.3	26.6	5.1	17.7	0.00	0.00	804	2.68
10/31/92	46.2	34.9	40.6	23.4	6.3	28.0	0.04	0.01	804	1.15

MONTHLY TEMPERATURES				WIND SPEED		PRECIPITATION	PRESSURE		
Mean High (°F)	Mean Low	Mean	Mean Dew-Mean point	Monthly (mph)	Maximum	Monthly Total	Monthly Maximum	Monthly Average	Total
63.3	39.5	51.4	23.8	7.4	48.8	0.59	0.08	813.9	109.59




Figure 5: Wind Rose for the Rocky Flats Plant - October 1992

# Appendix A

## Radiation Standards for Protection of the Public

### Calculation of Potential Plant Contribution to Public Radiation Dose

The primary standards for protection of the public from radiation are based on radiation dose. Radiation dose is a means of quantifying the biological damage or risk of ionizing radiation. The unit of radiation dose is the rem or the millirem (1 rem = 1,000 mrem). Radiation protection standards for the public are annual standards, based on the projected radiation dose from a year's exposure to or intake of radioactive materials.

Radiation dose is a calculated value. It is calculated by multiplying radioactivity concentrations in air and water or on contaminated surfaces by assumed intake rates (for internal exposures) or by exposure times (for external exposure to penetrating radiation), then by the appropriate radiation dose conversion factors. That is:

$$\text{Radiation Dose} = \frac{\text{Radioactivity Concentration} \times \text{Intake Rate/Exposure Time} \times \text{Dose Conversion Factor}}{1}$$

Radioactivity concentrations can be determined either by measurements in the environment or by calculations using computer models. These computer models perform airborne dispersion/dose modeling of measured building radioactivity effluents and estimated diffuse source term emissions (e.g., from resuspension from contaminated soil areas).

Assumed intake rates and dose conversion factors used are based on recommendations of national and international radiation protection advisory organizations, such as the National Council on Radiation Protection and Measurements (NCRP) and the International Commission on Radiological Protection (ICRP).

Radioactive materials of importance in calculating radiation dose to the public from Rocky Flats Plant (RFP) activities include plutonium, uranium, americium, and tritium. Alpha radiation emissions from plutonium, uranium, and americium are primary contributors to the projected radiation dose.

#### DOE Radiation Protection Standards for the Public

##### ICRP-Recommended Standards for all Pathways:

Temporary Increase - 500 mrem/year  
Effective Dose Equivalent  
(with prior approval of DOE EH-2)

Normal Operations - 100 mrem/year  
Effective Dose Equivalent

##### EPA Clean Air Act Standards for the Air Pathway Only:

10 mrem-year Effective Dose  
Equivalent

**DOE Derived  
Concentration Guides for  
Radionuclides of Interest at  
the Rocky Flats Plant**

**Air Inhalation:**

Radionuclide (pCi/m <sup>3</sup> )	DCG
Plutonium-239, -240	0.02

**Water Ingestion:**

Radionuclide	DCG (pCi/l)
Plutonium-239, -240	30
Americium-241	30
Uranium-233, -234	500
Uranium-238	600

Potential public radiation dose commitments, which could have resulted from plant operations and from background (i.e., non-Plant) contributions, are calculated from average radionuclide concentrations measured at the Department of Energy (DOE) property boundary and in surrounding communities. Inhalation and water ingestion are the principal potential pathways of human exposure.

On February 8, 1990, DOE adopted DOE Order 5400.5, "Radiation Protection of the Public and the Environment," a radiation protection standard for DOE environmental activities (US 90). This standard incorporates guidance from the International Commission on Radiological Protection (ICRP), as well as from the Environmental Protection Agency Clean Air Act air emission standards (as implemented in 40 CFR 61, Subpart H). Included in DOE Order 5400.5 is a revision of the dose limits for members of the public. Tables of radiation dose conversion factors currently used for calculating dose from intakes of radioactive materials were issued in July 1988 (US88a, US88b). The dose factors are based on the ICRP Publications 30 and 48 methodology and biological models for radiation dosimetry. The DOE Order 5400.5 and the dose conversion factor tables are used for assessment of any potential RFP contribution to public radiation dose. On December 15, 1989, EPA published revised Clean Air Act air emission standards for DOE facilities (US89). DOE radiation standards for protection of the public are given in this Appendix and include the December 15, 1989, EPA Clean Air Act air pathway standards.

**DOE Derived Concentration  
Guides**

Secondary radioactivity concentration guides can be calculated from the primary radiation dose standards and used as comparison values for measured radioactivity concentrations. DOE provides tables of these "Derived Concentration Guides" - in Order 5400.5. Derived Concentration Guides (DCGs) are the concentrations that would result in an effective dose equivalent of 100 mrem from one year's chronic exposure or intake. In calculating air inhalation DCGs, DOE assumes that the exposed individual inhales 8,400 cubic meters of air at the calculated DCG during the year. Ingestion DCGs assume a water intake of 730 liters at the calculated DCG for the year. The table on page 40 lists the most restrictive air and water DCGs for the principal radionuclides of interest at the RFP.

**Compliance with EPA Clean  
Air Act Standards**

To determine compliance with the EPA air emissions standards, measured airborne effluent radioactivity emissions are entered into the EPA-approved atmospheric dispersion/dose calculation computer model, AIRDOS-PC, for calculation of the maximum radiation dose that an individual in the public could receive from the air pathway only.

For comparison with the annual radiation dose standards for protection of the public, the maximum annual effective dose equivalent that a member of the public could receive as a result of RFP activities is typically less than 1 mrem, or less than 1 percent of the recommended annual standard for all pathways.

**Dose Equivalent and Effective Dose Equivalent  
(EDE)**

Dose equivalent is a calculated value used to quantify radiation dose; it reflects the degree of biological effect from ionizing radiation. Differences in the biological effect of different types of ionizing radiation (e.g., alpha, beta, gamma, or x-rays) are accounted for in the calculation of dose equivalent.

EDE is a calculated value used to allow comparisons of total health risk (based primarily on the risk of cancer mortality) from exposures of different types of ionizing radiation to different body organs. It is calculated by first calculating the dose equivalent to those organs receiving significant exposures, multiplying each organ dose equivalent by a health risk weighting factor, and then summing those products. One millirem EDE from natural background radiation would have the same health risk as one millirem EDE from an artificially produced source of radiation.



## References

**US88a** DOE/EH-0070, "External Dose-Rate Conversion Factors for Calculation of Dose to the Public," United States Department of Energy, Asst. Secretary for Environment, Safety and Health, July 1988.

**US88b** DOE/EH-0071, "Internal Dose Conversion Factors for Calculation of Dose to the Public," United States Department of Energy, Asst. Secretary of Environment, Safety and Health, July 1988.

**US89** United States Environmental Protection Agency, Code of Federal Regulations 40 CFR 61, Subpart H, "National Emission Standards for Emissions of Radionuclides other than Radon from Department of Energy Facilities," Washington, D.C., December 15, 1989.

**US90** United States Department of Energy, DOE Order 5400.5, "Radiation Protection of the Public and the Environment," Washington, D.C., February 8, 1990.

## Appendix B

### **National Pollutant Discharge Elimination System/Federal Facilities Compliance Agreement Volatile Organic Compounds**

The following is a list of volatile organic compounds (VOCs) for which monitoring is required by the Environmental Protection Agency (EPA) National Pollutant Discharge Elimination System/Federal Facilities Compliance Agreement (NPDES/FFCA).

<u>Compound</u>	<u>PQL (µg/l)</u>	<u>Compound</u>	<u>PQL (µg/l)</u>
Benzene	5	1,3-dichloropropylene	5
Bromoform	5	Ethylbenzene	5
Methyl bromide	10	Methyl chloride	10
Carbon Tetrachloride	5	Methylene chloride	5
Chlorobenzene	5	1,1,2,2-tetrachloroethane	5
Chlorodibromomethane	5	Tetrachloroethylene	5
Chloroethane	10	Toluene	5
Chloroform	5	1,2-trans-dichloroethylene	5
Dichlorobromomethane	5	1,1,1-trichloroethane	5
1,1-dichloroethane	5	1,1,2-trichloroethane	5
1,2-dichloroethane	5	Trichloroethylene	5
1,1-dichloroethylene	5	Vinyl chloride	10
1,2-dichloropropane	5		



## **Appendix C**

### ***Colorado Water Quality Control Commission Standards***

The Colorado Water Quality Control Commission has promulgated new standards for the Walnut Creek and Woman Creek drainages downstream from the Rocky Flats Plant. The EPA has not yet written a new NPDES permit that reflects these standards; however, in the spirit of the Agreement in Principle completed between the DOE and the State of Colorado, the plant is attempting to meet the standards at this time.



# Appendix D

## Distribution

### Federal Agencies

US DOE, RFO  
Attn: R.M. Nelson, Jr.  
Bldg. 115

USEPA  
Attn: Dr. M. Lammering,  
R. Rutherford  
One Denver Place - Suite 1300  
999 18th Street  
Denver, CO 80202-2413

USEPA  
Attn: B. Lavelle  
999 18th Street, Suite 500  
8 HWM-FF  
Denver, CO 80202-2405

### State Government Agencies

Colorado Water Conservation Board  
Attn: N.C. Ioannides  
823 State Centennial Building  
1313 Sherman Street  
Denver, CO 80203

Denver Regional Council of  
Governments  
Attn: L. Mugler  
2480 W. 27th Avenue, #200B  
Denver, CO 80211

Department of Natural Resources  
Attn: B. Hamlett III  
1313 Sherman Street  
Denver, CO 80203

Rocky Flats Environmental  
Monitoring Council  
Attn: G. Swartz  
1536 Cole Blvd., Suite 325  
Denver West Office Park #4  
Golden, CO 80401

### City Governments

City of Arvada  
Utilities Division  
Attn: M. Mauro  
8101 Ralston Road  
Arvada, CO 80002

City of Boulder  
Office of the City Manager  
Attn: J. Piper, A. Struthers  
P.O. Box 791  
Boulder, CO 80302

City of Broomfield  
Attn: H. Mahan, K. Schnoor  
#6 Garden Office Center  
P.O. Box 1415  
Broomfield, CO 80038-1415

City of Fort Collins  
Office of the City Manager  
Attn: S. Burkett  
300 La Porte  
Fort Collins, CO 80525

City of Northglenn  
Attn: T. Ambalam  
11701 Community Center Drive  
Northglenn, CO 80233-1099

City of Thornton  
Attn: J. Ethredge, City Manager  
9500 Civic Center Drive  
Thornton, CO 80229-1120

City of Westminster  
Attn: W. Christopher, S. Ramer  
4800 W. 92nd Avenue  
Westminster, CO 80030

Denver Water Department  
Quality Control  
Attn: J. Dice  
1600 W. 12th Avenue  
Denver, CO 80254

### Health Departments

Boulder City/County Health  
Department - Division of  
Environmental Health  
Attn: T. Douville, V. Harris  
3450 Broadway  
Boulder, CO 80020

Colorado Department of Health  
4300 Cherry Creek Drive South  
Denver, CO 80222-1530  
Attn: J. Berardini, J. Bruch, R. Fox,  
P. Frohardt, D. Holme, J. Jacobi,  
E. Kray, A. Lockhart, P. Nolan  
R. Quillin, J. Sowinski, R. Terry,

Jefferson County Health Department  
Attn: Dr. M. Johnson, C. Sanders  
260 South Kipling  
Lakewood, CO 80226

Tri County District Health  
Attn: S. Salyards  
4301 E. 72nd Avenue  
Commerce City, CO 80022

### Environmental

Advance Sciences, Inc.  
Attn: D. Kaskie, M.G. Waltermire  
405 Urban Street, Suite 401  
Lakewood, CO 80228

American Friends Service Co.  
Attn: T. Rauch  
1535 High Street, 3rd Floor  
Denver, CO 80218

Doty and Associates  
F.H. Elaha  
2303 Table Heights Drive  
Golden, CO 80401

Environmental Information Network  
Attn: P. Elofson-Gardine  
8470 W. 52nd Place, Suite 9  
Arvada, CO 80002-3447

IT Corporation  
Attn: C. Rayburn  
5600 S. Quebec, Suite 280D  
Englewood, CO 80111

L.C. Holdings  
Attn: M. Jones  
18300 Hwy 72  
Golden, CO 80403-8222

Margie Reynolds  
8882 Comanche Drivet  
Longmont, CO 80503-8657

National Renewable Energy  
Laboratory  
Attn: R. Noun  
1617 Cole Blvd.  
Golden, CO 80402

PRC Environmental Management,  
Inc.  
Attn: R.J. Fox  
1099 18th Street, Suite 1960  
Denver, CO 80202

Peak Rock Spring Water  
Attn: S. Dolson  
4615 Broadway Street  
Boulder, CO 80304-0509

Rocky Flats Cleanup Commission  
Attn: K. Korkia  
1738 Wynkoop, Suite 302  
Denver, CO 80202

Sierra Club - Rocky Mountain  
Chapter  
Attn: Dr. E. DeMayo  
11684 Ranch Elsie Road  
Golden, CO 80203

W. Gale Biggs Associates  
Attn: Dr. W. Gale Biggs  
P.O. Box 3344  
Boulder, CO 80307

Woodward Clyde/ERCE  
Attn: W. Glasgow  
Stanford Place 3, Suite 415  
4582 S. Ulster Street Pkwy.  
Denver, CO 80237

Wright Water Engineers  
Attn: J. Jones, S. Kribs  
2490 W. 26th Avenue, Suite 100A  
Denver, CO 80211

### Other

National Center for Atmospheric  
Research  
Attn: S. Sadler  
P.O. Box 3000  
Boulder, CO 80307-3000

Physicians for Social  
Responsibility  
Attn: T. Perry  
1000 16th NW, Suite 810  
Washington, D.C. 20036

R.M. Borinsky  
13004 Lowell Court  
Broomfield, CO 80020

W.J. Jones  
10986 W. 77th Avenue  
Arvada, CO 80005

T.T. Matsuo  
11746 W. 74th Way  
Arvada, CO 80005

R.D. Morgenstern  
3213 W. 133rd Avenue  
Broomfield, CO 80020

J.K. Natale  
11767 W. 74th Way  
Arvada, CO 80005

L.S. Newton  
5993 W. 75th Avenue  
Arvada, CO 80003

F.H. Shoemaker  
13631 W. 54th Avenue  
Arvada, CO 80002

D.S. Smith  
11122 Seton Place  
Westminster, CO 80030

D.L. Weiland  
7648 Owens Court  
Arvada, CO 80005

S.M. Yasutake  
6381 West 74th Place  
Arvada, CO 80003

### EG&G Rocky Flats

Rocky Flats Plant Public Reading  
Room  
c/o Front Range Community College  
3645 W. 112th Avenue  
Westminster, CO 80037

R.L. Benedetti, Acting Associate  
General Manager Environmental  
Restoration Management

B.M. Bowen, EPM/Air Quality  
Division

E.A. Brovsky, General Chemistry

M.S. Brugh, Gen. Spect. Laboratory

S.A. Buckie, Op. Health Physics

D.A. Cirrincione, EPM/  
Environmental Protection and Waste  
Reporting

J.A. Cuicci, Liquid Waste

S.L. Cunningham, Info. Security

N.M. Daugherty, EPM/Air Quality  
Division

N.S. Demos, ERM/Facility  
Operations

J.R. Dick, Analytical Labs

L.A. Doerr, Op. Health Physics

G.D. Elliott, FPM Program  
Management

E.W. Ellis, Technical Development

N.L. Erdmann, EPM/Environmental  
Protection and Waste Reporting

G.R. Euler, EPM/Air Quality  
Division

V.T. Guettlein, EPM/Surface Water

T.G. Hedahl, Associate General Manager Environmental & Waste Management	N.R. Stallcup, EPM/Environmental Protection and Waste Reporting
D.I. Hunter, General Laboratory	D. Stein, Mechanical Utilities
J.E. Janke, ERM/Remediation Reporting Management	M.T. Sullivan, Radiation Protection
H. Jordan, Safety Analysis & Risk Assessment	C. Trice, Analytical Labs
T.G. Kalivas, EPM/Air Quality Division	J.M. Wilson, Director, Communications
P.J. Laurin, ERM/Remediation Reporting Management	K.T. Wanebo, EPM/Environmental Protection and Waste Reporting
R.D. Lindberg, ERM/Env. Science and Technology	J.O. Zane, General Manager
F.G. McKenna, Chief Counsel	J. Zarret, Analytical Labs
W.E. Osborne, EPM/Air Quality Division	K. Zbryk, Analytical Labs
J.G. Paukert, Media Relations	
B.J. Pauley, EPM/Air Quality Division	
V.L. Peterson, Safety Analysis & Risk Assessment	
D.R. Pierson, Pondrete Ops.	
F. Primozić Waste Quality Engineering	
A.J. Read, Analytical Labs	
R.S. Roberts, Remediation Programs Division	
C.M. Sanda, Community Relations	
J.K. Schwartz, Media Communications	
C.A. Sedlmayr, Administration	
G.H. Setlock, Acting Director Environmental Protection Management	
T.A. Smith, Community Relations	



